

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

HARDY COUNTY PSD BAKER, WV3301613

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 2/1/2026 and 2/28/2026, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
38, MONITORING, ROUTINE (IESWTR/LT1), MINOR TURBIDITY Missing 1 sample 95 pt turbidity	2/1/2026 to 2/28/2026

What happened? What is being done? (Describe corrective action)

One of the turbidity test results from testing completed on February 20, 2026 was not recorded on the Monthly Operational Report for the Baker Water Plant. The test was completed as required and the results were within the acceptable range, however the test result was not recorded on the necessary paperwork.

For more information, please contact Hardy County PSD at 304-530-3048
(Contact name) (Phone number)
Or Hardy County PSD, PO Box 900, Moorefield, WV 26836
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **HARDY COUNTY PSD BAKER**

State Water System ID #: WV3301613

Date Distributed: 5/27/26